CSM®

» Municipal Drinking Water



Gloucester Water Treatment Plant

Gloucester County, Virginia





Plant Information

APPLICATION

• FEED SOURCE

PERMEATE CAPACITY

• PRETREATMENT

THETHEATIVIENT

• ELEMENT MODEL

• RO TRAIN ARRAY

• NUMBER OF TRAINS

SYSTEM RECOVERY

• END USER

• INSTALLATION

Municipal drinking water

Groundwater

2 MGD

5 micron cartridge filters

RE8040-BE (Brackish Water)

16:8 (2-stage, 7 elements per pressure vessel)

2

75-80%

Gloucester County

August 2009

General Information

CSM Brackish Water spiral wound RO elements are used at the Gloucester County Water Treatment Plant to provide the community with safe, clean and great tasting potable water. Because the RO system treats groundwater sourced from two wells with different depths and of two significantly different water qualities, plant operation and permeate quality will differ depending on which well the RO system is treating.

Technical Information

Operating Conditions	Well #1	Well #2
SDI	2.5-3.7	2.8-3.9
Temperature (°C)	24–26	23–28
Feed Conductivity (µS/cm)	4000-4300	6700-7200
Permeate Conductivity (µS/cm)	60-75	170–185
Feed Pressure (psi)	200	240
Interstage Pressure (psi)	180	220
Concetrate Pressure (psi)	165	210
Recovery (%)	78–80	75–78
Flux (GFD)	14.9	14.9