NE8040-HRM



Special grade NF membrane to selectively remove hardness

SPECIFICATIONS:

General Features

Permeate flow rate¹: 11,000 GPD (41.6 m³/day)

MgSO₄ rejection ¹: 99.0%

CaCl₂ rejection ²: 90 - 95%

Effective membrane area: 400 ft² (37.2 m²)


- 1. The stated product performance is based on data taken after 30 minutes of operation at the following test conditions:
 - 2,000 mg/L MgSO₄ solution at 75 psig (0.52 MPa) applied pressure
 - 15% recovery
 - 77 °F (25 °C)
 - pH 6.5-7.0
- 2. The stated product performance is based on data taken after 30 minutes of operation at the following test conditions:
 - 500 mg/L CaCl₂ solution at 75 psig (0.52 MPa) applied pressure
 - I5% recovery
 - 77 ∘F (25 ∘C)
 - pH 6.5-7.0
- 3. Minimum MgSO₄ rejection is 98%.
- 4. Permeate flow rate for each element may vary +30 / -15%.
- 5. Elements are supplied as dry-type. Dry elements are sealed in a poly bag and individually boxed.

Membrane type: Thin-Film Composite
Membrane material: Polyamide (PA)

Element configuration: Spiral-Wound, FRPWrapping

Dimensions and Weight

Model Name	A	В	С	Weight	Part Number	
					Inter-connector	Brine Seal
NE8040-HRM	40.0 inch (1,016 mm)	7.9 inch (200 mm)	1.12 inch (28.5 mm)	15 kg	SWA01049	SWA01043



- 1. Each membrane element supplied with one brine seal, one interconnector (coupler) and four o-rings.
- 2. All NE8040 elements fit nominal 8.0 inch (203.2 mm) I.D. pressure vessels.

The information provided in this document is solely for informative purposes. It is the user's responsibility to ensure the appropriate usage of this product. Toray Advanced Materials Korea Inc. assumes no obligation, liability or damages incurred for the misuse of the product or for the information provided in this document. This document does not express or implies any warranty as to the merchantability or fitness of the product.

Page 1 of 2 Rev.1.0 March 2020

NE8040-HRM



Special grade NF membrane to selectively remove hardness

APPLICATION DATA:

Operating Limits	· Max. Pressure Drop / Element	15 psi (0.1 MPa)		
	· Max. Pressure Drop / 240" Vessel	60 psi (0.41 Mpa)		
	· Max. Operating Pressure	600 psi (4.14 MPa)		
	· Max. Feed Flow Rate	75 gpm (17.0 m³/hr)		
	· Min. Concentrate Flow Rate	16 gpm (3.6 m³/hr)		
	· Max. Operating Temperature	I I 3 ∘F (45 ∘C)		
	· Operating pH Range	3.0-10.0		
	· CIP pH Range	2.0-11.0		
	· Max.Turbidity	I.0 NTU		
	· Max. SDI (15 min)	5.0		
	Max. Chlorine Concentration	< 0.05 mg/L		
Design Guidelines for Various	· Wastewater Conventional (SDI < 5)	8–12 gfd		
Water Sources	· Wastewater Pretreated by UF/MF (SDI < 3)	10–14 gfd		
	· Seawater, Open Intake (SDI < 5)	7–10 gfd		
	Seawater, Beach Well (SDI < 3)	8–12 gfd		
	· Surface Water (SDI < 5)	12–16 gfd		
	· Surface Water (SDI < 3)	13–17 gfd		
	· Well water (SDI < 3)	13–17 gfd		
	· RO permeate (SDI < I)	21–30 gfd		
Saturation Limits	· Langlier Saturation Index (LSI)	<+1.5		
(Using Antiscalants) T	· Stiff and Davis Saturation Index (SDSI)	<+0.5		
	· CaSO ₄	230% saturation		
	· SrSO ₄	800% saturation		
	· BaSO ₄	6,000% saturation		
	· SiO ₂	100% saturation		
	[†] The above saturation limits are typically accepted by proprietary antiscalant manufacturers. It is the user's responsibility to ensure proper chemical(s) and concentration are dosed ahead of the membrane system to prevent scale			

GENERAL HANDLING PROCEDURES

- Elements contained in the boxes must be kept dry at room temperature (7-32°C; 40-95°F) and should not be stored in direct sunlight.
- Permeate from the first hour of operation should be discarded to flush out the preservative solution.
- Used elements should be immersed in a preservative solution during storage, shipping and system shutdowns to prevent biological growth and freezing. The standard storage solution contains 1% by weight sodium bisulfite or sodium metabisulfite (food grade). For short term storage (i.e. one week or less) 1% by weight sodium metabisulfite solution is adequate for preventing biological growth.
- · Keep elements moist at all times after initial wetting.
- Avoid excessive pressure and flow spikes.

formation anywhere within the membrane system. Membrane elements fouled or damaged due to scale formation are not covered by the limited warranty.

- Only use chemicals compatible with the membrane elements and components. Use of such chemicals may void the element limited warranty.
- Permeate pressure must always be equal or less than the feed/concentrate pressure. Damage caused by permeate back pressure voids the element limited warranty.