NE8040-ARM70





SPECIFICATIONS:

General Features

Permeate flow rate¹: 6,000 GPD (22.7 m³/day)

MgSO₄ rejection 1: 99.0% CaCl₂ rejection ²: min. 90.0% 370 ft² (34.4 m²) Effective membrane area:


- 1. The stated product performance is based on data taken after 30 minutes of operation at the following test conditions:
 - 2,000 mg/L MgSO₄ solution at 75 psig (0.52 MPa) applied pressure
 - I5% recovery
 - 77 °F (25 °C)
 - pH 6.5-7.0
- 2. The stated product performance is based on data taken after 30 minutes of operation at the following test conditions:
 - 500 mg/L CaCl₂ solution at 75 psig (0.52 MPa) applied pressure
 - I5% recovery
 - 77 ∘F (25 ∘C)
 - pH 6.5-7.0
- 3. Minimum MgSO₄ rejection is 98%.
- 4. Permeate flow rate for each element may vary +30 / -15%.
- 5. Elements are supplied as dry-type. Dry elements are sealed in a poly bag and individually boxed.

Membrane type: Thin-Film Composite Membrane material: Polyamide (PA)

Element configuration: Spiral-Wound, FRP Wrapping

Dimensions and Weight

Model Name	A B C Weig	Woight	Part Number			
Model Name		В		weight	Inter-connector	Brine Seal
NE8040-ARM70	40.0 inch (1,016 mm)	7.9 inch (200 mm)	1.12 inch (28.5 mm)	15 kg	SWA01049	SWA01043



- 1. Each membrane element supplied with one brine seal, one interconnector (coupler) and four o-rings.
- 2. All NE8040 elements fit nominal 8.0 inch (203.2 mm) I.D. pressure vessels.

The information provided in this document is solely for informative purposes. It is the user's responsibility to ensure the appropriate usage of this product. Toray Advanced Materials Korea Inc. assumes no obligation, liability or damages incurred for the misuse of the product or for the information provided in this document. This document does not express or implies any warranty as to the merchantability or fitness of the product.

Page 1 of 2

NE8040-ARM70





APPLICATION DATA:

Operating Limits	 Max. Pressure Drop / Element 	15 psi (0.1 MPa)
	Mary Duranting Duran / 240"\/assal	(0 -a: (0 (1 M-a)

Max. Pressure Drop / 240" Vessel
 Max. Operating Pressure
 Max. Feed Flow Rate
 Min. Concentrate Flow Rate
 Max. Operating Temperature
 Max. Operating Temperature
 Operating PH Range
 Operating Temperature
 Operating Temperature
 Operating DH Range
 Operating Temperature
 Operating Temperature
 Operating DH Range
 Operating DH Range

CIP pH Range 0–11.0
 Max.Turbidity 1.0 NTU
 Max. SDI (15 min) 5.0

· Max. Chlorine Concentration < 0.05 mg/L

Design Guidelines for Various Water Sources

Wastewater Conventional (SDI < 5)	8–12 gfd
Wastewater Pretreated by UF/MF (SDI < 3)	10–14 gfd
Seawater, Open Intake (SDI < 5)	7–10 gfd
Seawater, Beach Well (SDI < 3)	8–12 gfd
Surface Water (SDI < 5)	12–16 gfd
Surface Water (SDI < 3)	13–17 gfd
Well water (SDI < 3)	13–17 gfd
RO permeate (SDI < I)	21–30 gfd

Saturation Limits (Using Antiscalants)[†]

Langlier Saturation Index (LSI)
 Stiff and Davis Saturation Index (SDSI)
 +1.5
 <+0.5

CaSO₄
 SrSO₄
 BaSO₄
 SiO₂
 230% saturation
 800% saturation
 6,000% saturation
 100% saturation

[†]The above saturation limits are typically accepted by proprietary antiscalant manufacturers. It is the user's responsibility to ensure proper chemical(s) and concentration are dosed ahead of the membrane system to prevent scale formation anywhere within the membrane system. Membrane elements fouled or damaged due to scale formation are not covered by the limited warranty.

GENERAL HANDLING PROCEDURES

- Elements contained in the boxes must be kept dry at room temperature (7–32°C; 40–95°F) and should not be stored in direct sunlight.
- Permeate from the first hour of operation should be discarded to flush out the preservative solution.
- Used elements should be immersed in a preservative solution during storage, shipping and system shutdowns to prevent biological growth and freezing. The standard storage solution contains 1% by weight sodium bisulfite or sodium metabisulfite (food grade). For short term storage (i.e. one week or less) 1% by weight sodium metabisulfite solution is adequate for preventing biological growth.
- · Keep elements moist at all times after initial wetting.
- Avoid excessive pressure and flow spikes.
- Only use chemicals compatible with the membrane elements and components. Use of such chemicals may void the element limited warranty.
- Permeate pressure must always be equal or less than the feed/concentrate pressure. Damage caused by permeate back pressure voids the element limited warranty.